

Monthly Fire Extinguisher Inspection



Check these details during a monthly fire extinguisher inspection.

- Confirm the extinguisher is visible, unobstructed, and in its designated location, hung at waist height with signage.
- Verify the locking pin is intact and the tamper seal is unbroken. Examine the extinguisher for obvious physical damage, corrosion, leakage, or clogged nozzle.
- Confirm the pressure gauge or indicator is in the green range, and lift the extinguisher to ensure it is still full.
- Make sure the operating instructions on the nameplate are legible and facing outward.
- Check the last professional service date on the tag. (A licensed fire extinguisher maintenance contractor must have inspected the extinguisher within the past 12 months.)
- Initial and date the back of the tag.

| YEAR | TYPE | LOCATION | INSPECTION DATE | SIGNATURE |
|-----------|------|----------|-----------------|-----------|
| January | | | | |
| February | | | | |
| March | | | | |
| April | | | | |
| May | | | | |
| June | | | | |
| July | | | | |
| August | | | | |
| September | | | | |
| October | | | | |
| November | | | | |
| December | | | | |